



GENERAL NOTES:

1. ALL CONCRETE SHALL BE CLASS A
2. IN ALL CASES WHERE STANDARD IRON PIPE IS TO BE USED WITH TYPE B MANHOLE, A FLEXIBLE JOINT SHALL OCCUR NOT MORE THAN TWO (2) FEET FROM THE INSIDE FACE OF THE MANHOLE.

CONTRACTOR NOTES:

1. SONOTUBE FORMS MAY BE USED AT CONTRACTOR'S OPTION AS APPROVED BY THE ENGINEER.

