



NOTES:

1. FOR LOCATION WITH SEPERATED SIDEWALK, HYDRANT TO BE CENTERED TWO (2) FEET BEHIND BACK OF CURB.
2. CURB TO BE PAINTED WITH RED CURB MARKING PAINT EIGHT (8) FEET ON BOTH SIDES OF HYDRANT.
3. INSTALL BLUE CENTER LANE MARKER ADJACENT TO CENTER LINE OF FIRE HYDRANT.



<p>CITY OF OROVILLE DEPARTMENT OF PUBLIC WORKS</p>		
<p>STANDARD FOR FIRE HYDRANT INSTALLATION</p>		
<p>DRAWN BY. SG</p>	<p>RICK WALLS, P.E. DIRECTOR OF PUBLIC WORKS DEPARTMENT</p>	<p>SHEET 1 OF 1 MS-05</p>